



CHAPTER 143
ARTICLE 9 - BUILDING CODE COUNCIL, RESIDENTIAL CODE COUNCIL, AND NORTH CAROLINA STATE BUILDING CODE

N.C.G.S. § 143-143.7.

Elevator safety requirements for certain residential rental accommodations.

SOURCE	LAST AMENDMENT IN THIS TEXT	RETRIEVED	SOURCE FINGERPRINT
General Statutes of North Carolina, as published by the General Assembly	No amendment history on record	21 September 2026, 02:54 UTC	81e2b3dc67595ba6602370fd - 8bd1b9649890dd16159818a1 - 42934b04e870ae5e

§ 143-143.7(a) Notwithstanding the requirements of G.S. 143-139(d), any elevator in a private residence, cottage, or similar accommodation subject to taxation under G.S. 105-164.4F shall meet the following requirements:

- (1) The gap between the hoistway face of the landing door, the door space guard, or the door baffle and the hoistway face of the car door as well as the door of the car or gate itself must meet the following requirements:
- a.Horizontal sliding car doors and gates shall be designed and installed such that the total of the gap between the hoistway face of the landing door, the door space guard, or the door baffle and the hoistway face of the car door or gate, after the car door or gate has been subject to a force of 75 pounds applied horizontally on an area four inches by four inches at right angles to and at any location on the car door or gate when fully closed, shall be no more than four and three-quarters inches.
- b.Folding car doors shall be designed and installed such that the total of the gap between the hoistway face of landing door, the door space guard, or the door baffle and the hoistway face of the car door, after the car door has been subject to a force of 75 pounds applied horizontally using a four-inch diameter sphere at any location within the folds of the door when fully closed, shall be no more than four and three-quarters inches.
- c.When the same 75-pound force is applied in the same manner to the horizontal sliding car door or gate or to the folding car door, there shall be no permanent

deformation of the door or gate and the door or gate shall not be displaced from its guides or tracks.

(2) Repealed by Session Laws 2023-68, s. 1, effective June 30, 2024.

§ 143-143.7(b)

If any property subject to this section has an elevator that does not comply with subsection (a) of this section, the landlord shall prevent the operation of the elevator until the elevator has been brought into compliance by meeting the following requirements:

- (1) If the elevator does not comply with sub-subdivision a. or b. of subdivision (1) of subsection (a) of this section, then the landlord shall install a hoistway door space guard, a full height door baffle, or a door baffle that is at least 31.75 inches in height, each of which shall be nonremovable and shall be designed and installed to withstand a force of 75 pounds applied horizontally using a four-inch diameter sphere at any location, until the maximum gap is in compliance with sub-subdivision a. or b. of subdivision (1) of subsection (a) of this section.
- (2) If the elevator door or gate does not comply with sub-subdivision c. of subdivision (1) of subsection (a) of this section, then the landlord shall replace it with a door or gate that complies with sub-subdivision c. of subdivision (1) of subsection (a) of this section.

§ 143-143.7(c)

Upon installation of a door baffle, door space guard, door, or gate meeting the requirements of subdivision (1) or (2) of subsection (b) of this section, the landlord shall provide the State Fire Marshal with one of the following:

- (1) A statement signed by a professional elevator installer certifying installation of the door baffle, door space guard, door, or gate meeting the requirements of subsection (b) of this section.
- (2) A receipt for purchase of the door baffle, door space guard, door, or gate meeting the requirements of subsection (b) of this section, a signed statement by the landlord stating the date of installation, and photographs depicting the door baffle, door space guard, door, or gate as installed.

§ 143-143.7(d)

For purposes of this section, "elevator" means a hoisting and lowering mechanism equipped with a car or platform which moves in guides, and which serves two or more floors of a building or structure.

§ 143-143.7(e) Any person who violates subsection (b) of this section by permitting the continued operation of an elevator that does not comply with subsection (a) of this section shall be guilty of a Class 2 misdemeanor. (2022-56, s. 1; 2023-68, s. 1; 2023-108, s. 1(a); 2023-151, s. 11.63.)

END OF SECTION TEXT

APPARATUS FOLLOWS — DERIVED, NOT ENACTED

APPARATUS II
2 AUTHORITIES

Authorities referenced

Every G.S. cross-reference appearing in the text of this section, in order of first appearance. Nothing is characterized; the operative language is quoted from the section itself.

REFERENCE	APPEARS IN	OPERATIVE LANGUAGE IN THIS SECTION
G.S. 143-139(d)	(a)	"Notwithstanding the requirements of"
G.S. 105-164.4F	(a)	"similar accommodation subject to taxation under"

APPARATUS III

Citation

FULL SECTION
N.C. Gen. Stat. § 143-143.7 (2026).

PINPOINT
N.C. Gen. Stat. § 143-143.7(a) (2026).

Pinpoint keys are set in the left margin of the text rather than line numbers: subsection designators are stable across editions and paper sizes, line numbers are not.

COLOPHON

Provenance

This document reproduces the text of one section of the General Statutes of North Carolina from a source file whose SHA-256 digest is printed on every page. The digest fixes the bytes this export was made from; if the State's file changes, the digest will not match.

The text of the section is unaltered. Subsection designators have been moved from the run of text into the margin. The amendment history and the table of authorities are derived from the section by mechanical extraction — they add no characterization of the law.

This is not the official text. The official text is published by the General Assembly of North Carolina.

